

**PAUL WELCH INC.**

MECHANICAL ELECTRICAL CIVIL ENGINEERING  
1984 S.W. BILTMORE ST. SUITE#114  
PORT SAINT LUCIE, FL 34984  
PHONE (772) 785 - 9888  
FAX (772) 785-9933

APRIL 20, 2012


RE: RHEEM / RUUD DESIGNSTAR LOAD CALCULATION  
SOFTWARE PROGRAM

TO WHOM IT MAY CONCERN:

PLEASE BE ADVISED THAT WE HAVE REVIEWED THE RHEEM/RUUD DESIGNSTAR LOAD CALCULATION SOFTWARE TO DETERMINE IF IT COMPLIES WITH THE LATEST ADOPTED BUILDING ENERGY CODES AND CONFORMS TO ACCEPTED ENGINEERING DESIGN PRACTICE. OUR REVIEW DEMONSTRATED THAT THE RHEEM/RUUD DESIGNSTAR LOAD CALCULATION SOFTWARE COMPUTES BUILDING HEATING AND COOLING LOADS AND SIZES EQUIPMENT IN A MANNER CONSISTENT WITH GOOD ENGINEERING PRACTICE AND APPROVED HEATING AND COOLING LOAD CALCULATION METHODOLOGIES. IT IS IN OUR OPINION THAT THE DESIGNSTAR SOFTWARE FULLY COMPLIES WITH FLORIDA BUILDING CODE 2010 ENERGY CONSERVATION CODES SECTIONS 403.6 HEATING AND COOLING EQUIPMENT AND 101.4.7.1.2 REPLACEMENT EQUIPMENT SIZING.

THANK YOU FOR YOUR ATTENTION TO THIS MATTER.

SUBMITTED BY:



PAUL WELCH P.E.  
FL REG NO. 29945  
PW:PP